

EGOLF RECOMMENDATION

EGR 90:2015

related test method	EN 1364-3
subject	Gaskets
reference of original query	EGOLF TC2, N735, Helpdesk 2014-09
EGR for attention of CEN	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
if yes, please state TC/WG/TG	To be included in TC2 formal Liaison Report to CEN TC 127 (ref. WG1)

Problem

In the standard EN 1364-3:2014, the direct field of application of the gaskets are described. Could you please explain to me what is allowed, increasing of the gaskets or decreasing?

Recommendation

An increase seems to be more logical than a decrease.
The proposition is thus to allow only increase (up to 50%) but not decrease. The first sentence of EN 1364-3 § 13.4.4.1.1 is confusing and could be clarified. The second sentence is deemed to give the correct information.