

EGOLF AGREEMENT 025-2016

| | |
|---|--|
| Subject of Agreement | Classification report according to EN 13501-5, based on testing according to CEN/TS 1187, test method 1 |
| Related test standard | EN 13501-1 based on testing to CEN/TS 1187 tm1 |
| Date of issue | 2014 |
| Reference original query | TC1 helpdesk 2013-08 |
| Previous publication number (if applicable) | EGR 81 |
| Keywords (max. 20) | roof, classification, report, measured, limit, value |

Problem:

There are differences amongst EGOLF laboratories in the way how test results of testing according to CEN/TS EN 1187, test method 1, are used in the classification reports according to EN 13501-5.

All labs are using the table as given B.4.2.1 of EN 13501-1. But some labs are writing just Y(es) or N(o) in all cells of this table (related to the limit values stated in the second column), also there where they have to measure specific values. Other labs write these specific values they measured in the tests in this table.

Can EGOLF members agree to write the measured values (where relevant) in the classification report? Relevant values are all values for which a limit value is given in the second column of the table in clause B. 4.2.1 of EN 13501-5.

Agreement

EGOLF members agree that measured values (where relevant) must be stated in the classification report. Relevant values are all values for which a limit value is given in the second column of the table in clause B. 4.2.1 of EN 13501-5.